

Date Prepared 7/2004
Revised 6/10/05
Prepared By P. Watt

BMP EOC #22

TITLE: Aboveground Tank Labeling

Regulatory Citation: 6 NYCRR Part 613.5 (a)

Applicability: The following tanks must be labeled:

Tank I.D.	Location

Purpose: To identify the tank and list its capacity to prevent overfilling.

Person or

Department Responsible: Associate Coordinator of Business Services

Schedule: Not Applicable.

Procedures: The tanks must be labeled with the following information:

Registration Number	Tank Contents	Working/Design Capacity (Gallons)
001	#2 fuel oil	2,000/1800
004	#2 fuel oil	550/495

In addition each of the tanks must be equipped with a level gauge and the fill ports and manhole cover labeled with a green hexagon.

Record keeping: Not Applicable.

Record Location: Not Applicable.

Contact: Asso. Coord of Business Services 273-1900

#22 ASTLabeling